

**Requirements for Field Test Instruments and Measurements for Balanced Single Twisted-Pair
 Cabling**

TABLE OF CONTENTS

1			
2			
3			
4			
5			
6	1	SCOPE	1
7	2	NORMATIVE REFERENCES	1
8	3	DEFINITIONS, ABBREVIATIONS AND ACRONYMS, UNITS OF MEASURE	1
9	3.1	General	1
10	3.2	Definitions	1
11	3.3	Acronyms and abbreviations	2
12	3.4	Units of measure	2
13	3.5	Variables	2
14	4	TEST INSTRUMENTS	3
15	4.1	General	3
16	4.2	Data reporting requirements	3
17	4.2.1	Parameters to be reported	3
18	4.2.2	Wire Map	3
19	4.2.3	Length	4
20	4.2.3.1	Physical length vs. electrical length	4
21	4.2.3.2	NVP calibration	4
22	4.2.4	Pass/fail results	4
23	4.2.5	Detailed results	5
24	4.2.6	Summary results	5
25	4.3	Field measurement procedures	7
26	4.3.1	Consistency checks for field testers	7
27	4.3.2	Administration	7
28	4.3.3	Test equipment connectors and cords	7
29	4.4	Field tester measurement accuracy requirements	8
30	4.4.1	General	8
31	4.4.2	Nominal accuracy	8
32	4.4.3	Length and propagation delay performance parameters	10
33	4.4.4	Performance parameters for Level SP-I and SP-II field testers	11
34	4.4.5	Performance parameters for measurement of cabling for resistance parameters ...	13
35	4.5	Procedures for determining field tester parameters	14
36	4.5.1	General	14
37	4.5.2	Output signal balance (OSB)	14
38	4.5.3	Common mode rejection (CMR)	14
39	4.5.4	Dynamic accuracy	15
40	4.5.5	Source/load return loss	15
41	4.5.6	Random noise floor	16
42	4.5.7	Directivity	16
43	4.5.8	Reflection Tracking	16
44	4.5.9	Source match	17
45	4.5.10	Return loss of remote termination	17
46	4.5.11	Constant error term of the length measurement function	17
47	4.5.12	Error term proportional to length of the length measurement function	17
48	4.5.13	Constant error term of the propagation delay measurement function	18
49	4.5.14	Error term proportional to the propagation delay of the propagation delay measurement	
50	function	18	
51	4.5.15	Constant error term of dc loop resistance for measurement of cabling for resistance	
52	parameters	18	
53	4.5.16	Error term proportional to the dc loop resistance for measurement of cabling for resistance	
54	parameters	18	

55	4.6	Measurement error models.....	18
56	4.6.1	General.....	18
57	4.6.2	Error model for the insertion loss measurement function	19
58	4.6.3	Error model for the return loss measurement function.....	19
59	4.6.4	Error model for the TCL measurement function.....	20
60	4.6.5	Error model for the TCTL measurement function.....	20
61	4.6.6	Error model for the propagation delay measurement function.....	21
62	4.6.7	Error model for the length measurement function.....	21
63	4.6.8	Error model for dc loop resistance	21
64	4.7	Alien crosstalk measurement requirements and procedures	21
65	4.7.1	General.....	21
66	4.7.2	Test parameters	21
67	4.7.3	Test configurations	22
68	4.7.4	Test equipment for measuring alien crosstalk in installed cabling	22
69	4.7.5	Channel alien crosstalk testing.....	22
70	4.7.6	Permanent link testing.....	22
71	4.7.7	Alien crosstalk measurement floor	22
72	4.7.8	Measurement floor of the test instrument for the channel test configuration	22
73	4.7.9	Measurement floor of the test instrument with permanent link adapter test cords ..	23
74	4.7.10	Alien crosstalk measurements	24
75	4.7.10.1	Measuring ANEXT loss in the channel configuration.....	24
76	4.7.10.2	Measuring AFEXT loss in the channel configuration	24
77	4.7.10.3	Measurement of permanent link alien crosstalk	25
78	4.7.11	Processing measurement data.....	25
79	4.7.11.1	Computing PSANEXT loss and PSAACRF	25
80	4.7.11.2	Significance condition testing.....	25
81	4.7.11.3	Applying measurement floor correction to alien crosstalk	25
82	4.8	Comparison measurement procedures	26
83	4.8.1	General.....	26
84	4.8.2	General requirements.....	26
85	4.8.2.1	Test adapters	26
86	4.8.2.2	Comparison methods	27
87	Annex A	(informative) - Typical measurement accuracy of reference laboratory measurement systems	
88	30		
89	Annex B	(informative) - Derivation of Level SP-I and SP-II Source Match and Reflection Tracking terms	
90	33		
91	Annex C	(informative) - Bibliography	37
92			

93 **LIST OF FIGURES**

94 Figure 1 - Relationship between relevant TIA Standards 4

95 Figure 2 - Reverse Pair 4

96 Figure 3 - Example of NVP Calibration 4

97 Figure 4 - Block diagram to measuring output signal balance 14

98 Figure 5 - Block diagram to measuring common mode rejection 15

99 Figure 6 - Block diagram for measuring dynamic accuracy 15

100 Figure 7 - Block diagram for measuring directivity 16

101 Figure 8 - Schematic diagram for testing the measurement floor of the channel test configuration 23

102 Figure 9 - Schematic diagram for testing the measurement floor of the permanent link test configuration 23

103 Figure 10 - Schematic diagram to measure channel ANEXT loss 24

104 Figure 11 - - Schematic diagram to measure channel AFEXT loss 24

105 Figure 12 - Special patch cord for the baseline and channel test comparison 27

106 Figure 13 - Special patch cord for permanent link test comparison 27

107 Figure 14 - Example of observed Level SP-II accuracy 29

108

109 Figure B-1 - Error model for one-port VNA measurement 33

110

111

112 **LIST OF TABLES**

113 Table 1 - Field tester summary reporting requirements 6

114 Table 2 – Limits to be used for calculating accuracy (TBD) 8

115 Table 3 - Nominal measurement accuracies at pass/fail limits (TBD) 9

116 Table 4 - Accuracies for resistance measurements for measurement of cabling for resistance parameters
117 (TBD) 9

118 Table 5 - Field tester requirements including accuracy for length and propagation delay (TBD) 10

119 Table 6 - Level SP-I field tester accuracy performance (TBD) 11

120 Table 7 - Level SP-II field tester accuracy performance (TBD) 12

121 Table 8 - Performance parameters for measurement of cabling for resistance parameters (TBD) 13

122

123 Table A.1 - Typical laboratory equipment accuracy performance parameters 30

124 Table A.2 - Measurement performance parameters at key frequencies (TBD) 31

125 Table A.3 - Absolute reference load return loss (TBD) 31

126 Table A.4 - Predicted measurement worst case accuracy using laboratory equipment at channel limits
127 (TBD) 32

128

129

FOREWORD

(This foreword is not part of the Standard)

ANSI/TIA-1152, Requirements for Field Test Instruments and Measurements for Balanced Twisted-Pair Cabling, was published. ANSI/TIA-1152 addresses 4-pair cabling systems. This standard will address field testing of single-pair cabling systems.

Approval of this Standard

TIA standards documents are developed within the Technical Committees of the TIA and the standards coordinating committees of the TIA standards board. Members of the committees serve voluntarily and without commission. The companies that they represent are not necessarily members of the TIA. The standards developed within the TIA represent a consensus of the broad expertise on the subject. This expertise comes from within the TIA as well as those outside of the TIA that have an expressed interest. The viewpoint expressed at the time that this standard was approved was from the contributors' experience and the state of the art at that time. Users are encouraged to verify that they have the latest revision of the Standard.


This standard has been prepared by the TR-42.7 Subcommittee and approved by the TIA Engineering Committee TR-42 and the American National Standards Institute (ANSI).

ANSI/TIA reviews standards every 5 years. At that time, standards are reaffirmed, rescinded, or revised according to the submitted updates. Updates to be included in the next revision should be sent to the committee chair or to ANSI/TIA.

Relationship to other TIA standards and documents

The following are related standards regarding various aspects of structured cabling that were developed and are maintained by Engineering Committee TIA TR-42. An illustrative diagram of the relationship to other relevant TIA standards is given in Figure 1.

- ANSI/TIA-568.0, *Generic Telecommunications Cabling for Customer Premises*
- ANSI/TIA-568.1, *Commercial Building Telecommunications Infrastructure Standard*
- ANSI/TIA-568.2, *Balanced Twisted-Pair Telecommunications Cabling and Components Standard*
- ANSI/TIA-568.3, *Optical Fiber Cabling and Components Standard*
- ANSI/TIA-568.4, *Broadband Coaxial Cabling and Components Standard*
- ANSI/TIA-568.5, *Balanced Single Twisted-Pair Telecommunications Cabling and Components Standard*
- ANSI/TIA-569, *Telecommunications Pathways and Spaces*
- ANSI/TIA-570, *Residential Telecommunications Infrastructure Standard*
- ANSI/TIA-606, *Administration Standard for Telecommunications Infrastructure*
- ANSI/TIA-607, *Generic Telecommunications Bonding and Grounding (Earthing) for Customer Premises*
- ANSI/TIA-758, *Customer-Owned Outside Plant Telecommunications Infrastructure Standard*
- ANSI/TIA-862, *Structured Cabling Infrastructure Standard for Intelligent Building Systems*
- ANSI/TIA-942, *Telecommunications Infrastructure Standard for Data Centers*
- ANSI/TIA-1005, *Telecommunications Infrastructure Standard for Industrial Premises*
- ANSI/TIA-1179, *Healthcare Facility Telecommunications Infrastructure Standard*
- ANSI/TIA-4966, *Telecommunications Infrastructure Standard for Educational Facilities*
- ANSI/TIA-4994, *Standard for Sustainable Information Communications Technology*
- ANSI/TIA-5017, *Telecommunications Physical Network Security Standard*



178

179

Figure 1 - Relationship between relevant TIA Standards

180

181 In addition, the following documents may be useful to the reader:

182

- 183 • *National Electrical Safety Code® (NESC®)* (IEEE C 2);
- 184 • *National Electrical Code® (NEC®)* (NFPA 70)

185
186 Useful supplements to this Standard include the BICSI *Telecommunications Distribution Methods Manual*,
187 the *Outside Plant Design Reference Manual*, and the *Information Transport Systems Installation Methods*
188 *Manual*. These manuals provide practices and methods by which many of the requirements of this standard
189 are implemented.
190

191 **Annexes**

192 Annexes A, B and C are informative and are not considered requirements of this Standard.

193

DRAFT

194 **1 SCOPE**

195 This Standard specifies requirements for field test instruments and includes procedures for testing
196 balanced single twisted-pair cabling to meet the specifications in the ANSI/TIA-568.5 and
197 ANSI/TIA-568.7 standards. This Standard specifies the reporting and measurement accuracy
198 requirements of field test instruments. This Standard contains methods to verify field test instrument
199 accuracy by comparing the field test instrument measurements against laboratory equipment
200 measurements specified in ANSI/TIA-568.5.

201 **2 NORMATIVE REFERENCES**

202 The following documents are referred to in the text in such a way that some or all of their content
203 constitutes requirements of this document. For dated references, only the edition cited applies. For
204 undated references, the latest edition of the referenced document (including any amendments)
205 applies.

206
207 ANSI/TIA-568.2 Balanced Twisted-Pair Telecommunications Cabling and Components Standard

208
209 ANSI/TIA-606 Administration Standard for Commercial Telecommunications Infrastructure

210
211 ANSI/TIA-568.5 Balanced Single Twisted-Pair Telecommunications Cabling and Components
212 Standard
213

214 **3 DEFINITIONS, ABBREVIATIONS AND ACRONYMS, UNITS OF MEASURE**

215 **3.1 General**

216 For the purpose of this Standard, the following definitions, acronyms and abbreviations and units
217 of measure apply.

218 **3.2 Definitions**

219 **administration:** The method for labeling, identification, documentation, and usage needed for
220 installation, moves, additions and changes of the telecommunications infrastructure.

221
222 **cabling:** A combination of all cables, jumpers, cords, and connecting hardware.

223
224 **common mode rejection:** The ratio of the measured differential voltage to a common mode
225 voltage applied to the load port.

226
227 **insertion loss:** The power loss resulting from the insertion of a component, link or channel (often
228 referred to as attenuation).

229
230 **link:** A transmission path between two points, not including equipment and cords.

231
232 **nominal velocity of propagation:** The percentage of the speed of light at which signal travels in
233 a cable.

234
235 **output signal balance:** The ratio of the output common mode voltage to the output differential
236 voltage generated by a source port.

237
238 **patch cord:** A cord used to establish connections on a patch panel.

239
240 **patch panel:** A connecting hardware system that facilitates cable termination and cabling
241 administration using patch cords.

242
243 **power sum alien near-end crosstalk:** A computation of the unwanted signal coupling from

244 multiple uncorrelated transmitters at the near-end into a pair measured at the near-end.
245
246 **power sum attenuation to alien crosstalk ratio, far-end:** A computation of the unwanted signal
247 coupling from multiple uncorrelated transmitters at the near-end into a pair measured at the far-
248 end.
249
250 **return loss:** A ratio expressed in dB of the power of the outgoing signal to the power of the reflected
251 signal.
252
253 **screen:** An element of a cable formed by a shield.
254
255 **shield:** A metallic layer placed around a conductor or group of conductors.
256
257 **telecommunications:** The transmission and reception of information by cable, radio, optical or
258 other electromagnetic systems.

259 3.3 Acronyms and abbreviations

260	ANSI	American National Standards Institute
261	CMR	Common mode rejection
262	DMCM	Differential mode plus common mode
263	OSB	Output signal balance
264	NVP	Nominal velocity of propagation
265	PSAACRF	Power sum attenuation to alien crosstalk ratio, far-end
266	PSANEXT	Power sum alien near-end crosstalk
267	RF	Radio frequency
268	TIA	Telecommunications Industry Association

269 3.4 Units of measure

270	dB	decibel
271	m	meter
272	MHz	megahertz
273	ns	nanosecond
274	µs	microsecond

275 3.5 Variables

276	f	frequency, in MHz
-----	-----	-------------------

277
278
279

280 **4 TEST INSTRUMENTS**

281 **4.1 General**

282 This Standard specifies the reporting and accuracy performance requirements of field testers and
283 provides additional guidelines for field testing procedures. Two levels of field testers based on
284 frequency ranges are defined:

- 285
- 286 • SP-I (TBD) : 0.1 MHz to 20 MHz
 - 287 • SP-II (TBD) : 1 MHz to 600 MHz

288 Note that the use of Level SP in the document applies to both Level SP-I and Level SP-II.
289 Special requirements apply when testing alien crosstalk. Refer to 4.7 for more information. 4.8
290 contains methods to compare the results of field testers against those obtained using laboratory
291 equipment.

292 **4.2 Data reporting requirements**

293 **4.2.1 Parameters to be reported**

294 The field test instrument shall be able to measure and report the following link parameters for the
295 permanent link and channel test configurations as defined in ANSI/TIA-568.5.

- 296
- 297 Wire map, including shield connection if present
 - 298 Insertion loss
 - 299 Length
 - 300 Return loss, measured from near-end
 - 301 Return loss, measured from far-end
 - 302 Transverse Conversion Loss, measured from near-end
 - 303 Transverse Conversion Loss, measured from far-end
 - 304 Transverse Conversion Transfer Loss, measured from near-end
 - 305 Transverse Conversion Transfer Loss, measured from far-end
 - 306 Propagation delay
 - 307 DC loop resistance
 - 308 DC resistance unbalance if shield is present

309 **4.2.2 Wire Map**

310 The wire map test is intended to verify pin-to-pin termination at each end and check for installation
311 connectivity errors. For each of the 2 conductors and shield if present in the cabling, the wire map
312 indicates:

- 313
- 314 a) continuity to the remote end
 - 315 b) short between the two conductors and shield if present
 - 316 c) reversed pair
 - 317 d) continuity of the screen along the path of the cabling to remote end (if required)

318 A reversed pair occurs when the polarity of one pair is reversed at one end of the link (also called
319 a tip/ring reversal). Refer to Figure 2 for an illustration of a reversed pair.

320



321

322
323

Figure 2 - Reverse Pair

324 **4.2.3 Length**

325 This clause contains specific guidelines for determination of length during field tests.

326 **4.2.3.1 Physical length vs. electrical length**

327 The physical length of the permanent link or channel is the sum of the physical length of the cabling
328 components between the two end points. Physical length of the permanent link or channel may be
329 determined by physically measuring the length(s) of the cable segment(s), calculated from the
330 length markings on the cable segments when present, or estimated from the electrical length
331 measurement. The electrical length is derived from the propagation delay of the signals and
332 depends on the construction and material properties of the cable (see ANSI/TIA-568.2).
333


334 When physical length is determined from electrical length, the physical length of the link calculated
335 using electrical delay shall be reported and used for making the pass or fail decision. The pass or
336 fail criteria is based on the maximum length allowed for the channel or permanent link as specified
337 in ANSI/TIA-568.5 plus the nominal velocity of propagation (NVP) uncertainty of 10 %.
338

339 NOTE – Calibration of NVP is critical to the accuracy of length measurements and can
340 improve the accuracy. See 4.2.3.2.

341 **4.2.3.2 NVP calibration**

342 NVP calibration is performed by measuring the length of a cable segment that is longer than 30 m
343 using a tape measure or observing the length markings on the cable and comparing the physical
344 length to the measured shortest of all pairs electrical length reported by the field test instruments.
345 Field test instruments shall contain provisions for setting the measured electrical length based on
346 the shortest delay so that this NVP will be used to compute length from propagation delay
347 measurements during subsequent measurements.
348

349 A convenient electrical length measurement is made by terminating the cable segment with jacks
350 and testing the length using permanent link adapters. See Figure 3.
351



352
353
354

Figure 3 - Example of NVP Calibration

355 **4.2.4 Pass/fail results**

356 A pass or fail result for each parameter shall be determined by the specified limits for that
357 parameter. Refer to 4.4 for detailed information on measurement accuracy requirements. An
358 overall pass or fail condition shall be determined by the results of the required individual tests. Any
359 fail shall result in an overall fail. In order to achieve an overall pass condition, all individual results
360 shall be pass. Measurements reported by the field tester shall have a specified accuracy. Accuracy
361 is the difference between the measured value reported by the field tester from the actual value. The
362 field test instrument shall be capable of reporting the data at all measured points as defined in 4.2.5

363 and uploading the data to a PC or an external system and provide summary results as defined in
364 4.2.6.

365
366 NOTE – The field tester accuracy equations do not contain an allowance for the plug
367 variability of different adapters connected to a permanent link under test.

368 **4.2.5 Detailed results**

369 The field tester shall be capable of reporting all connectivity information, as well as the measured
370 values of every parameter at every frequency data point.

371 The detailed results shall include a pass/fail result for each of the parameters, as applicable. In
372 addition the field tester shall save the measured data for all tested parameters.

373 **4.2.6 Summary results**

374 Detailed information may be required or desired in certain circumstances. In general, summary
375 performance information is sufficient. The field tester shall be capable of reporting the summary
376 information in Table 1 as a minimum.

DRAFT

377

Table 1 - Field tester summary reporting requirements

Function	Measured from either end (if measurement from both directions is not required)	Measured from opposite end (if measurement from both ends is required)
Wire Map	All connectivity, including shields (if present) pass/fail	Not Required
Insertion Loss	Worst case insertion loss Test limit at worst case Frequency at worst case pass/fail	Not Required
Length	Length Test limit pass/fail	Not Required
Return loss	Worst case margin Return loss at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case return loss Test limit at worst case Return loss at worst case Frequency at worst case	Worst case margin Return loss at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case return loss Test limit at worst case Return loss at worst case Frequency at worst case
TCL	Worst case margin TCL at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case TCL Test limit at worst case TCL at worst case Frequency at worst case	Worst case margin TCL at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case TCL Test limit at worst case TCL at worst case Frequency at worst case
TCTL	Worst case margin TCTL at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case TCTL Test limit at worst case TCTL at worst case Frequency at worst case	Worst case margin TCTL at worst case margin. Test limit at worst case margin. Frequency at worst case margin pass/fail AND Worst case TCTL Test limit at worst case TCTL at worst case Frequency at worst case
Propagation Delay	Worst case propagation delay Test limit at worst case pass/fail	Not Required
DC loop resistance	Worst case dc loop Resistance Test limit at worst case pass/fail	Not Required

378 Due to accuracy considerations, when the measured insertion loss is less than 3 dB, the measured
 379 return loss shall not be used in determining a fail. Return loss values greater than 25 dB may be
 380 reported as ">25 dB".

381 **4.3 Field measurement procedures**

382 **4.3.1 Consistency checks for field testers**

383 The field tester manufacturer shall make available to the user a simple procedure for verifying,
384 reporting, and recording the consistency of the field tester in the field. The following procedures
385 are recommended.

386

387 1 Repeatability of tests on a reference link

388

389 The owner of the field tester should construct a reference link. Repeated measurements
390 on this link should result in the same results within the magnitude of the accuracy
391 specifications. The accuracy specification for the field tester is referenced at the limit line.
392 Comparisons should be made at the worst case results across the frequency band.

393

394 2 Consistency of tests by testing the same link in opposite directions

395

396 Any link can be measured at first by connecting the local field tester unit to one end of the
397 cabling and the remote field tester unit to the other end of the cabling. After performing a
398 test, the locations of local field tester unit and remote field tester unit are exchanged.
399 Additionally the units shall be changed whilst the adapters remain at the same end of test
400 as the reference measurement, and following manufacturer recommendations for
401 connection of adapters to field testers.

402

403 3 Reproducibility of tests on a reference link

404

405 Repeat measurements including new connection of the DUT to the field tester (e.g. plug in
406 and out of the PL adapter). At least 3 people should repeat the test at least 10 times.

407

408 All worst case magnitudes should remain the same within 1.4 times the accuracy specification of
409 the test function, except for return loss and TCL measurements. For return loss and TCL, the local
410 return loss and TCL results obtained during the first test should be compared to the remote return
411 loss and TCL results obtained during the second test. Similarly, the remote return loss and TCL
412 results obtained during the first test should be compared to the local return loss and TCL results
413 during the second test. These results should not differ by more than 1.4 times the relevant accuracy
414 specifications.

415 **4.3.2 Administration**

416 In addition to pass/fail indications, worst case measured values of test parameters should be
417 recorded per ANSI/TIA-606.

418 **4.3.3 Test equipment connectors and cords**

419 To maintain measurement accuracy, only test cords and adapters that are qualified by the test
420 equipment manufacturer for the channel or link test configuration shall be used.

421

422 Connecting hardware and test cords have a limited life-cycle and should be periodically inspected
423 for wear resulting from multiple mating cycles and bending during normal use. Consult with test
424 equipment manufacturers for the life cycle of the connectors and cords.

425

426 Any reconfiguration of cabling components after testing may change the performance and thus
427 invalidate previous test results. If confirmation of performance is desired the cabling shall be
428 re-tested.

429 **4.4 Field tester measurement accuracy requirements**

430 **4.4.1 General**

431 Minimum performance levels have been identified for Single Pair field testers applicable to the
432 baseline, permanent link and channel configuration. The performance requirements for Single Pair
433 field testers are as further described in this clause. Accuracy is a function of the characteristics of
434 the field tester and the transmission characteristics of the cabling. Each accuracy level has its own
435 set of performance requirements as further described in this clause. Error models for each of the
436 measurements provide estimates for the measurement accuracy for each parameter to be
437 measured. The error models use the most important performance parameters that are expected
438 to influence measurement accuracy. However, there may be additional sources of measurement
439 error, which are not reflected in this error model, depending on the implementation of the
440 measurement circuitry in the field tester.

441
442 Therefore, in addition to performance requirements for the properties of field testers, methods to
443 compare the results obtained by field testers with those using laboratory methods are specified.
444 Laboratory methods are described in 4.8. The deviation of the two results shall be no more than
445 the sum total of the estimated measurement accuracy of the field tester and estimated
446 measurement accuracy of the laboratory measurement system.
447

448 **4.4.2 Nominal accuracy**

449 The worst-case accuracy of a field test instrument can be calculated by inserting the applicable
450 channel or permanent link requirements specified in ANSI/TIA-568.5 into the error models
451 referenced in 4.6. In practice, worst case conditions of all parameters at all frequencies are
452 highly unlikely. A first order approximation of nominal accuracy is 0.5 of the worst case computed
453 accuracy. The actual accuracy may be better than the nominal accuracy. For detailed accuracy
454 information, refer to the manufacturer's specifications. The limits used to calculate accuracy of
455 the field test instrument are specified in Table 2.

456 **Table 2 – Limits to be used for calculating accuracy (TBD)**

457

Level of field tester	Accuracy	Limit used to calculate accuracy
SP-I	Baseline	Category SP1 permanent link limit
	Permanent Link	Category SP1 permanent link limit
	Channel	Category SP1 channel limit
SP-II	Baseline	[TBD] limit
	Permanent Link	[TBD] limit
	Channel	[TBD] limit

458
459

460 Table 3 shows the measurement accuracy using a compliant field tester.

461
462

Table 3 - Nominal measurement accuracies at pass/fail limits (TBD)

Level of field tester	Test parameter	Freq (MHz)	Baseline accuracy at perm. link limits (± dB)	Permanent link accuracy at perm. link limits (± dB)	Channel accuracy at channel limits (± dB)
SP-I	Insertion loss	1	0.6	0.7	0.7
		20	0.6	0.7	0.7
	Return loss	1	1.4	1.7	1.5
		20	1.4	1.7	1.5
	TCL	1	1.4	1.7	1.5
		20	1.4	1.7	1.5
TCTL	1	1.4	1.7	1.5	
	20	1.4	1.7	1.5	
SP-II	Insertion loss	100	0.6	0.7	0.7
		250	1.0	1.1	1.3
		600	1.3	1.4	1.6
	Return loss	100	1.4	1.7	1.5
		250	1.2	2.1	1.9
		600	1.1	2.2	2.0
	TCL	100	1.4	1.7	1.5
		250	1.2	2.1	1.9
		600	1.1	2.2	2.0
	TCTL	100	1.4	1.7	1.5
		250	1.2	2.1	1.9
		600	1.1	2.2	2.0

463

464 **Table 4 - Accuracies for resistance measurements for measurement of cabling for**
465 **resistance parameters (TBD)**

Level of field tester	Test parameter	Baseline accuracy at perm. link limits	Permanent link accuracy at perm. link limits	Channel accuracy at channel limits
SP-I	DC loop resistance	±(0.5Ω+1% dc loop resistance)		
	DC resistance unbalance	±(0.025Ω +0.3% dc loop resistance)		
SP-II	DC loop resistance	±(0.5Ω+1% dc loop resistance)		
	DC resistance unbalance	±(0.025Ω +0.3% dc loop resistance)		

466

467 **4.4.3 Length and propagation delay performance parameters**

468 Field testers shall comply with length, propagation delay, and delay skew performance parameters,
 469 independent of Level as shown in table 5.

470

471 NOTE - The length accuracy does not include the uncertainty of NVP calibration.

472 **Table 5 - Field tester requirements including accuracy for length and propagation delay**
 473 **(TBD)**

Level of field tester	Parameter	Length	Propagation Delay
SP-I	Measurement range	0 m – 1000 m	0 μ s – 9 μ s at 1 MHz
	Resolution	0.1 m	1 ns
	Constant error term	1 m up to 1000 m	5 ns
	Proportional error term	4 % (TBD) up to 1000 m	4 %
	Error at 100 m length	5 m	27.7 ns
	Error at 1000 m length	41 m (TBD)	227.5 ns
SP-II	Measurement range	0 m – 100 m	0 μ s – 1 μ s at 10 MHz
	Resolution	0.1 m	1 ns
	Constant error term	1 m up to 100 m	5 ns
	Proportional error term	4 % up to 100 m	4 %
	Error at 30 m length	2.2 m	12 ns
	Error at 100 m length	5 m	27 ns

474

475 **4.4.4 Performance parameters for Level SP-I and SP-II field testers**
 476 Level SP-I and SP-II field testers shall conform to the requirements in Table 6 and Table 7 for the
 477 baseline, permanent link, and/or channel test configurations. Methods to verify compliance of field
 478 tester requirements are specified in 4.5.

479 **Table 6 - Level SP-I field tester accuracy performance (TBD)**

Parameter	Baseline field tester	Field tester with Level SP-I permanent link adapter	Field tester with Level SP-I channel adapter	
Dynamic range	3 dB over test limit			<i>dB</i>
Amplitude resolution	0.1			<i>dB</i>
Frequency range and resolution	0.1 - 20 MHz : 20 kHz			<i>MHz</i>
Dynamic Accuracy IL	± 0.75			<i>dB</i>
Source/load return loss	0.1-20 MHz: 20 dB		0.1-20 MHz: 20 dB	<i>dB</i>
Random Noise Floor	0.1-20 MHz: 95 dB		0.1-20 MHz: 90 dB	<i>dB</i>
Output Signal Balance	0.1-20 MHz: 50 dB		0.1-20 MHz: 50 dB	<i>dB</i>
Common Mode Rejection	0.1-20 MHz: 50 dB		0.1-20 MHz: 50 dB	<i>dB</i>
Reflection Tracking	± 0.5			<i>dB</i>
Directivity	0.1-20 MHz: 30 dB		0.1-20 MHz: 30 dB	<i>dB</i>
Source Match	0.1-20 MHz: 30 dB		0.1-20 MHz: 30 dB	<i>dB</i>
Return loss of Termination	0.1-20 MHz: 25 dB		0.1-20 MHz: 25 dB	<i>dB</i>

480

481

Table 7 - Level SP-II field tester accuracy performance (TBD)

Parameter	Baseline field tester	Field tester with Level SP-II permanent link adapter	Field tester with Level SP-II channel adapter	
Dynamic range	3 dB over test limit			<i>dB</i>
Amplitude resolution	0.1			<i>dB</i>
Frequency range and resolution	1 - 31.25 MHz : 150 kHz 31.25 - 100 MHz : 250 kHz 100 - 250 MHz : 500 kHz 250 - 600 MHz : 1 MHz			<i>MHz</i>
Dynamic Accuracy IL	± 0.75			<i>dB</i>
Source/load return loss	1-600 MHz: 21- 9log(f/100) dB 20 dB max	1-600 MHz: 19- 9log(f/100) dB 20 dB max		<i>dB</i>
Random Noise Floor	1-600 MHz: 95 dB	1-600 MHz: 90dB		<i>dB</i>
Output Signal Balance	1-600 MHz: 40-20 log (f/100) dB 40dB max	1-600 MHz: 37-20 log (f/100) dB 40dB max		<i>dB</i>
Common Mode Rejection	1-600 MHz: 40-20 log (f/100) dB 40dB max	1-600 MHz: 37-20 log (f/100) dB 40dB max		<i>dB</i>
Reflection Tracking	± 0.5			<i>dB</i>
Directivity	1-600 MHz: 30,7- 9log(f/100) dB 30dB max	1-600 MHz: 28,7- 9log(f/100) 30dB max		<i>dB</i>
Source Match	1-600MHz: 20 dB	1-600MHz: 20 dB		<i>dB</i>
Return loss of Termination	1-600MHz: 21- 9log(f/100) dB 25 dB max	1-600MHz: 19- 9log(f/100) dB 25 dB max		<i>dB</i>

482

483 **4.4.5 Performance parameters for measurement of cabling for resistance parameters**

484 Field testers capable of measuring resistance parameters shall comply with Table 8.

485 **Table 8 - Performance parameters for measurement of cabling for resistance parameters**
 486 **(TBD)**

SP-I	DC loop resistance Resolution	0.1	Ω
	Constant error term of DC loop resistance E_{c,dc_r}	1	Ω
	Error term proportional to the DC loop resistance E_{d,dc_r}	x% (TBD)	%
SP-II	DC loop resistance Resolution	0.01	Ω
	Constant error term of DC loop resistance E_{c,dc_r}	0.5	Ω
	Error term proportional to the DC loop resistance E_{d,dc_r}	1%	%

487
 488

489 **4.5 Procedures for determining field tester parameters**

490 **4.5.1 General**

491 Field testers are designed with two units that are attached to opposite ends of the cabling to be
492 tested. Internal to these units are source and load ports that are used for measurements. The
493 following measurements shall be used to determine compliance with the applicable requirements,
494 and shall apply to the entire frequency range specified in these tables. The field testers shall include
495 functionality to make independent verification of field tester parameters.


496 **4.5.2 Output signal balance (OSB)**

497 This performance requirement is applicable to:

- 498 • TCL measurement and TCTL calculations

500 Output Signal Balance (OSB) is defined as the ratio of the output common mode voltage to the
501 output differential voltage generated by a source port. (V_d / V_c is used instead to make the value
502 positive per convention) as shown in Figure 4. The field test instrument shall be connected to
503 ground for the measurement as near as possible to the port to be measured. This shall provide a
504 low impedance path to instrument ground of the field test instrument over the specified frequency
505 range. The OSB compliance test shall be conducted without and with a polarity reversal.
506

507
508
509
510
511
512
513
514
515
516



517 **Figure 4 - Block diagram to measuring output signal balance**

518
519
520
521

Note: This test configuration differs from the test arrangements for measuring the OSB of baluns used in laboratory measurements. This effectively causes Z_c to become 25Ω .

522 **4.5.3 Common mode rejection (CMR)**

523 This performance requirement is applicable to:

- 524 • TCL measurement and TCTL calculations

525
526 Common Mode Rejection is defined as the ratio of the measured differential voltage to a common
527 mode voltage applied to the load port (V_c / V_m is used to make the value positive per convention)
528 as shown in Figure 5. The field test instrument shall be connected to measurement ground as near
529 as possible to the port to be measured. This connection shall provide a low impedance path to the
530 signal ground of the field tester over the specified frequency range. The CMR compliance test shall
531 be conducted without and with a polarity reversal.
532

533




Figure 5 - Block diagram to measuring common mode rejection

534

535 Note: This test configuration differs from the test arrangements for measuring the CMR of baluns
 536 used in laboratory measurements. This effectively causes Z_c to become 25Ω .

537 **4.5.4 Dynamic accuracy**

538 This performance requirement is applicable to:

539

- 540 • Insertion loss measurements

541

542 Dynamic accuracy is the accuracy of the measured value to an external voltage input as shown in
 543 Figure 6. The external voltage shall provide a minimum output source balance (OSB) signal of
 544 40 dB with a minimum return loss of 20 dB.




Figure 6 - Block diagram for measuring dynamic accuracy

545

546 V_i could be sourced by the field instrument under test and injected into the receiver through a
 547 resistive attenuator when the residual crosstalk is 30 dB below the injected signal level.

548 **4.5.5 Source/load return loss**

549 This performance requirement is applicable to:

550

- 551 • Insertion loss measurements
- 552 • TCL measurement and TCTL calculations

553

554 The source and load return loss of the insertion loss measurement functions shall be measured
 555 with a network analyzer calibrated relative to a reference DMCM resistor network with return loss
 556 of better than 40 dB over the frequency range of interest. The calibration shall include an
 557 impedance matching transformer/balun with better than 40 dB longitudinal conversion loss as
 558 specified in clause B.2 of ANSI/TIA-568.2.

559

560

$$\text{Return loss} \geq -20 \log \left(\frac{V_{\text{reflected}}}{V_{\text{incident}}} \right) \quad (1)$$

561 **4.5.6 Random noise floor**

562 This performance requirement is applicable to:

563

- 564 • Alien crosstalk parameter measurements

565

566 The random noise floor is the ratio of the measured voltage V_m when the source port voltage is
567 zero, to the source port voltage V_o under normal measurement conditions.

568

$$\text{Random Noise Floor} \geq -20 \log \left(\frac{V_m}{V_o} \right) \quad (2)$$

569

570 A procedure measuring voltage with an external voltmeter at the output of the detector is acceptable
571 if it demonstrates equivalency.

572

573 **4.5.7 Directivity**

574 This performance requirement is applicable to:

575

- 576 • Return loss measurements
- 577 • TCL measurements and TCTL calculations

578

579 Directivity is the signal that couples into the measurement channel and adds to the reflected signal
580 that is measured. It is measured by performing a return loss measurement when terminating the
581 test interface with a DMCM resistor network according to Figure 7 that have return loss better than
582 40 dB relative to a reference calibration resistor from 0.1 MHz to the upper frequency limit of the
583 category.

584




Figure 7 - Block diagram for measuring directivity

585

586 **4.5.8 Reflection Tracking**

587 This performance requirement is applicable to:

588

- 589 • Return loss measurements
- 590 • TCL measurements and TCTL calculations

591

592

593 Reflection Tracking is the response of the transducer used to determine the reflected signal. It is
594 determined from two measurements:

595
596
597
598
599
600
601
602

- Measurement of return loss with the pair shorted (the actual reflection coefficient is -1), as a function of frequency, and
- Measurement of return loss with the pair open (the actual reflection coefficient is +1), as a function of frequency.

Reflection Tracking error is given by equation (3) for Level SP field testers.

$$Tracking_{dB} \geq -20 \cdot \log \left(\left| \frac{2(\Gamma_{load} - \Gamma_{short})(\Gamma_{open} - \Gamma_{load})}{(\Gamma_{open} - \Gamma_{short})} \right| \right) \quad (3)$$

603
604
605

It should be noted that in equation (3) the reflection coefficients are linear vector quantities and not dB values.

606 4.5.9 Source match

607 This performance requirement is applicable to:

608
609
610
611

- Return loss measurements
- TCL measurements and TCTL calculations

612 Source match is a measurement of the reflected signal that is not absorbed by the return loss
613 measurement circuitry. The field tester should be first calibrated with traceable SOLT standards,
614 then Source Match is determined from the measurements of directivity, return loss with shorted pair
615 and return loss with open pair. With results of all measurements expressed in linear vector
616 quantities, the source match error is given by equation (4) for Level SP field testers. Any fixturing
617 required to interface the calibration load artifact shall not be included in the measurement.
618

$$Source_Match_{dB} = -20 \cdot \log \left(\left| \frac{(\Gamma_{open} + \Gamma_{short}) - 2\Gamma_{load}}{(\Gamma_{open} - \Gamma_{short})} \right| \right) \quad (4)$$

619

620 4.5.10 Return loss of remote termination

621 This performance requirement is applicable to:

622
623
624
625

- Return loss measurements
- TCL measurements and TCTL calculations

626 The requirements for return loss of the remote termination exceed those for the source/load return
627 loss of the insertion loss measurement functions. In order to perform this measurement a network
628 analyzer with S-parameter test set, capable of providing one-port calibration, shall be used as
629 described for the source/load return loss measurement of the insertion loss function. The return
630 loss of the termination of each pair shall be separately determined. DMCM terminations shall be
631 applied.

632 4.5.11 Constant error term of the length measurement function

633 The constant error term of the length measurement function is determined by connecting the local
634 unit to the remote unit through a short test cable and observing the reported length. The reported
635 length shall be less than the constant error term of the length measurement function.

636 4.5.12 Error term proportional to length of the length measurement function

637 The length of cabling with a total length of 100 m +/- 1% shall be measured using a tape measure.

638 The NVP calibration shall be performed. Then cabling with a known length of approximately 50 m
 639 shall be measured. The reported length shall deviate from the actual value by less than 1/2 the
 640 amount of the error constant proportional to length.

641 **4.5.13 Constant error term of the propagation delay measurement function**

642 The parameters that affect propagation delay accuracy include a constant error term E_c and a term
 643 E_d that is proportional to length of the link. The constant error term of the propagation delay
 644 measurement function is determined by connecting the local unit to the remote unit through a short
 645 test cable and measuring the propagation delay. The reported propagation delay shall be less than
 646 the constant error term of the propagation delay.

647 **4.5.14 Error term proportional to the propagation delay of the propagation delay**
 648 **measurement function**

649 The propagation delay of cabling with a total length of 100 m +/- 1% shall be measured using the
 650 reference measurement procedure. The propagation delay at 10 MHz is the reference value. Then
 651 the same cabling shall be connected to the field tester and the propagation delay measured. The
 652 reported value by the field tester minus the reported value measured when a very short connection
 653 was made to the same field tester shall deviate less from the error constant that is proportional to
 654 the propagation delay of the propagation delay measurement function.

655 **4.5.15 Constant error term of dc loop resistance for measurement of cabling for**
 656 **resistance parameters**

657 The procedure for determining the constant error term of dc loop resistance, $E_{c,dc,r}$, is to connect
 658 a connector to the field tester with shorts across each pair. The reported dc resistance in each case
 659 shall be less than the $E_{c,dc,r}$.

660 **4.5.16 Error term proportional to the dc loop resistance for measurement of cabling for**
 661 **resistance parameters**

662 The dc resistance of cabling with a total length of approximately 100 m shall be measured using a
 663 four-terminal ohmmeter with a specified accuracy of at least 0.1%. The dc resistance of the same
 664 cabling, measured with the field tester, less the observed resistance value with the pair shorted
 665 (constant error term of dc loop resistance) shall be less than the error constant term proportional
 666 to the dc resistance.
 667

$$E_{d,DC,r} = \frac{\Omega_{FieldTester} - E_{c,DC,r}}{\Omega_{FourWire}} \quad (5)$$

- 668
 669 $E_{d,DC,r}$ Error term proportional to dc loop resistance
 670 $E_{c,DC,r}$ Constant error term of dc loop resistance
 671 $\Omega_{FieldTester}$ The value of the dc loop resistance as measured on the field tester
 672 $\Omega_{FourWire}$ The value of the dc loop resistance as measured on the four-terminal ohmmeter
 673

674 **4.6 Measurement error models**

675 **4.6.1 General**

676 The measurement accuracy for the permanent link and channel is computed using the parameters
 677 in Table 6 and Table 7. The error models used to estimate the baseline measurement accuracy of
 678 the field tester are based upon the 12-parameter error model defined for network analyzer
 679 measurements with modifications and simplifications. There is no assurance that these
 680 simplifications and modifications are appropriate in every circumstance or that the error model is
 681 complete. Nevertheless, the computed estimated measurement accuracies from the error models
 682 shown in this clause are a reasonable indication of the measurement performance that may be

683 expected from a compliant field tester. The computed estimated measurement accuracy shall be in
684 harmony with the results from network analyzer comparisons.

685 4.6.2 Error model for the insertion loss measurement function

686 The error model for the insertion loss measurement function for Level SP field testers is expressed
687 in equation (6).
688

$$Accuracy_{IL}(dB) = E_{d,IL} + 20 \log_{10} \left[\frac{1 + 10^{\frac{-E_{RL,tester}}{10}}}{1 - 2 * 10^{\frac{-E_{RL,link} - E_{RL,tester}}{20}} - 10^{\frac{-E_{RL,tester} - E_{RL,link}}{10}} - 10^{\frac{-E_{RL,tester} - E_{IL,link}}{10}}} \right] \quad (6)$$

689

690 where:

691 $Accuracy_{IL}$ is the estimated accuracy of the insertion loss measurement function in dB
692 $E_{d,IL}$ is the dynamic accuracy of the field tester for insertion loss in dB
693 $E_{RL,tester}$ is the return loss of the field tester in dB
694 $E_{RL,link}$ is the return loss of the link in dB
695 $E_{IL,link}$ is the insertion loss of the link in dB

696

697 Assumptions:

- 698 • Dynamic accuracy adds directly to all other error terms.
- 699 • The error from source/load return loss of the field tester plus the impact of the source/load
700 interaction with the return loss of the link is added.
- 701 Impact from the test cable for the measurement of the connector used for the channel interface are
702 expected to have a significant impact on the source/load return loss of the field tester.

703

704 4.6.3 Error model for the return loss measurement function

705 The error model for the return loss measurement relates to contributions to inaccuracy at the input,
706 related to measurement of the reflected signal and contributions that are the result of reflections at
707 the remote termination of the cabling. The estimated return loss measurement error is given by
708 equation (7) for Level SP Pair field testers.
709

$$Error_{RL} = TR + 20 \cdot \log_{10} \left[\frac{1 + 10^{\frac{[A_{RL} - E_{DIR}]}{20}} + 10^{-\frac{[A_{RL} + E_{SM}]}{20}}}{10^{\frac{[A_{RL} - E_{TERM}(dB) - \sqrt{f}]}{20}} + 10^{\frac{[A_{RL} - E_{DIR} - E_{OSB}(dB) - E_{CMR}(dB)]}{20}}} \right] \quad (7)$$

710

711 where:

712 $Error_{RL}$ is the estimated accuracy of the return loss measurement function in dB
713 A_{RL} is the return loss amplitude in dB at which the error is computed
714 TR is Reflection Tracking error in dB
715 E_{DIR} is the directivity in dB
716 E_{SM} is the source match in dB
717 E_{TERM} is the return loss of the remote termination in dB in return loss mode
718 f is the frequency in MHz
719 E_{OSB} is the output signal balance of the field tester in dB
720 E_{CMR} is the common mode rejection of the field tester in dB

721

722 Assumptions:

- 723 • The Reflection Tracking error (like dynamic accuracy) is added directly to the remaining error
724 terms.

- 725 • The error from directivity and source match are added worst case, since the phase of one
- 726 component changes slowly while the other changes much faster. Therefore an “envelope”
- 727 worst case condition is assumed. The impact from the source match error is practically minor.
- 728 • The error caused by the reflection at the remote termination is added in a power sum manner
- 729 to the remainder of the error terms. It is attenuated by the assumed minimum round trip
- 730 insertion loss of the link under test.
- 731

732 4.6.4 Error model for the TCL measurement function

733 The error model for the TCL measurement function is expressed in equation (8).
734

$$\begin{aligned}
 Accy_{TCL} = & E_{d,TCL} + 20 \\
 & * \log_{10} \left[1 + 10^{\frac{-(E_{DMRL,tester} + E_{CMRL,tester})}{20}} + 10^{\frac{-(E_{DMRL,tester} + E_{DMRL,link})}{20}} \right. \\
 & \left. + 10^{\frac{-(E_{CMRL,tester} + E_{CMRL,link})}{20}} + \left\{ \left(10^{\frac{(A_{TCL} - E_{RTCL})}{10}} \right) + \left(10^{\frac{(A_{TCL} - E_{TCLNF})}{10}} \right) \right\}^2 \right] \quad (8)
 \end{aligned}$$

735

736 where:

- | | |
|-----------------------|--------------------------------------------------------------|
| 737 $Accy_{TCL}$ is | the estimated accuracy of the TCL measurement function in dB |
| 738 $E_{d,TCL}$ | is the dynamic accuracy of the tester for TCL in dB |
| 739 $E_{DMRL,tester}$ | is the differential mode return loss of tester in dB |
| 740 $E_{CMRL,tester}$ | is the common mode return loss of tester in dB |
| 741 $E_{DMRL,link}$ | is the differential mode return loss of link in dB |
| 742 $E_{CMRL,link}$ | is the common mode return loss of link in dB |
| 743 A_{TCL} | is the TCL signal amplitude for accuracy in dB |
| 744 E_{TCLNF} | is the TCL random noise floor of tester in dB |
| 745 E_{RTCL} | is the residual TCL of tester in dB |
| 746 | |

747 4.6.5 Error model for the TCTL measurement function

748 The error model for the TCTL measurement function is expressed in equation (9).
749

$$\begin{aligned}
 Accy_{TCTL} = & E_{d,TCTL} + 20 \\
 & * \log_{10} \left[\left(\frac{1 + 10^{\frac{-(E_{DMRL,tester} + E_{CMRL,tester})}{20}}}{\left(1 - 10^{\frac{-(E_{DMRL,tester} + E_{DMRL,link})}{20}} \right) \left(1 - 10^{\frac{-(E_{CMRL,tester} + E_{CMRL,link})}{20}} \right)} \right) \right. \\
 & \left. + \sqrt{\left(10^{\frac{(A_{TCTL} - E_{NFTCTL})}{10}} \right) + \left(10^{\frac{(A_{TCTL} - E_{RTCTL})}{10}} \right)} \right] \quad (9)
 \end{aligned}$$

750

751

752

753 where:

- | | |
|-----------------------|------------------------------------------------------------------|
| 754 $Accy_{TCTL}$ | is the estimated accuracy of the TCTL measurement function in dB |
| 755 $E_{d,TCTL}$ | is the dynamic accuracy of the tester for TCTL in dB |
| 756 $E_{DMRL,tester}$ | is the differential mode return loss of tester in dB |

757 $E_{CMRL,tester}$ is the common mode return loss of tester in dB
758 $E_{DMRL,link}$ is the differential mode return loss of link in dB
759 $E_{CMRL,link}$ is the common mode return loss of link in dB
760 A_{TCTL} is the TCTL signal amplitude for accuracy in dB
761 E_{NFTCTL} is the TCTL random noise floor of tester in dB
762 E_{RTCTL} is the residual TCTL of tester in dB
763

764 **4.6.6 Error model for the propagation delay measurement function**

765 The error of the propagation delay contains a constant error term and an error that is proportional
766 to propagation delay of the measured cabling. For a 100 meter limited distance, this error is
767 approximately proportional to length; see equation (10).
768

$$Error_{propagation_delay} = E_c + E_d \cdot propagation_delay \quad (10)$$

769

770 where:

771 E_c is the constant error term and

772 E_d is the error term proportional to the propagation delay of the cabling.

773 **4.6.7 Error model for the length measurement function**

774 The error model for length is identical to the error model for propagation delay since the length is a
775 constant times the NVP.
776

777 **4.6.8 Error model for dc loop resistance**

778 The error model for dc loop resistance is provided by the addition of the constant error term of dc
779 loop resistances ($E_{c,dc,r}$) and the error term proportional to dc loop resistance ($E_{d,dc,r}$).
780

781 **4.7 Alien crosstalk measurement requirements and procedures**

782 **4.7.1 General**

783 The methods in this section can be used to measure alien crosstalk properties of installed single-
784 pair cabling.

785 **4.7.2 Test parameters**

786 In addition to the parameters listed in 4.2.1, the field tester shall be able to measure the following
787 parameters for the permanent link and channel test configurations as defined in this document:
788

789 ANEXT loss

790 AFEXT loss

791

792 The field tester shall be able to report the following parameters for the permanent link and channel
793 test configurations as defined in this document:
794

795 PSANEXT loss

796 PSAACRF

797

798 The field tester shall report results and their associated test orientation (i.e. from the local end or
799 remote end).

800 **4.7.3 Test configurations**

801 Alien crosstalk testing in the field is conducted on the installed permanent link and channel
802 configurations. The illustrations in this annex show only one disturbing channel for simplicity.

803

804 NOTE - Alien cross-talk requirements for Single Pair channels and permanent links are
805 specified for bundled configurations containing only Single Pair cabling components.

806 **4.7.4 Test equipment for measuring alien crosstalk in installed cabling**

807 Figure 8 through Figure 11 illustrate a physical control channel between field testers. A physical
808 control channel is not a required implementation of this Standard. Other implementations are
809 possible if equivalence is demonstrated.

810 **4.7.5 Channel alien crosstalk testing**

811 The test interface to the test instrument consists of two jacks that exhibit an insignificant amount of
812 power sum alien crosstalk between them. One jack is connected to test instrument A, and the other
813 jack is connected to test instrument B. Provisions should be made for measurement control
814 purposes between the two test instruments. Refer to the recommendations of the manufacturer of
815 the test equipment used for the appropriate test implementation.

816

817 The reference plane of measurement is at the location that is defined for the channel as shown in
818 ANSI/TIA-568.5. Channels shall be tested with cords used in the channel and shall be kept as
819 much as possible in their normal use position during the tests.

820 **4.7.6 Permanent link testing**

821 The test interface consists of two test cords terminated with plugs. One test cord is connected to
822 test instrument A, and the other test cord is connected to test instrument B. Provision should be
823 made for measurement control purposes between test instrument A and test instrument B. Refer
824 to the recommendations by the manufacturer of the test equipment used for the appropriate test
825 implementation.

826

827 The reference plane of measurement shall be at the location that is defined for the permanent link.

828 **4.7.7 Alien crosstalk measurement floor**

829 The measurement floor of the test instrument shall meet or exceed the values in equation (11) to
830 a maximum requirement of 95 dB.

831

$$Measurement_Floor_{Test_Instrument} \geq 95 - 20\log\left(\frac{f}{100}\right) \quad (11)$$


832

833 The measurement floor of the test instrument shall be determined using an alien crosstalk
834 measurement with the configuration specified in 4.7.8 or 4.7.9.

835 **4.7.8 Measurement floor of the test instrument for the channel test configuration**

836 The measurement floor of the test instrument can be established in the channel test configuration
837 by terminating the channel with plugs that have DMCM terminations as shown in Figure 8. The
838 common mode point shall be connected to the shield if present.

839



840

841 **Figure 8 - Schematic diagram for testing the measurement floor of the channel test**
842 **configuration**

843
844 The power sum alien crosstalk measurement floor as a function of the expected maximum number
845 of disturbing channels shall meet the requirement in equation (12).
846

$$Measurement_Floor_{PSAXT,Nps} \geq Measurement_Floor_{TestInstrument} - 10 \log(N_{PS}) \text{ dB} \quad (12)$$

847

848 where:

849 $Measurement_Floor_{PSAXT,Nps}$ is the PSANEXT loss or PSAFEXT loss measurement floor in dB.

850


851 N_{PS} is the maximum expected number of disturbing channels.

852

853 The result of equation (12) shall exceed the appropriate pass/fail limit by 6 dB.

854 **4.7.9 Measurement floor of the test instrument with permanent link adapter test cords**

855 Alien crosstalk measurements are made by terminating the test cords with jacks that have DMCM
856 terminations as shown in Figure 9. The common mode point shall be connected to the shield if
857 present. The same requirements as specified in 4.7.8 apply.
858




859

860 **Figure 9 - Schematic diagram for testing the measurement floor of the permanent link test**
861 **configuration**

862 **4.7.10 Alien crosstalk measurements**

863 **4.7.10.1 Measuring ANEXT loss in the channel configuration**

864 The schematic diagram for the ANEXT loss test from one end is shown in Figure 10.
 865



866

867 **Figure 10 - Schematic diagram to measure channel ANEXT loss**

868


869

870 The test instrument A is connected to the disturbed channel, and the test instrument B is connected to a disturbing channel. ANEXT loss tests from the other end can be made by swapping the test instrument with the terminations at the opposite end.
 871
 872

873 **4.7.10.2 Measuring AFEXT loss in the channel configuration**

874 Measuring AFEXT loss from one end requires that the test instrument A is connected to the disturbed channel and the test instrument B is connected to a disturbing channel.
 875
 876

877 Assuming that test instrument A and test instrument B have a separate measurement control communication path connection or field tester communication channel, the schematic diagram is as shown in Figure 11. AFEXT loss tests from the other end can be made by swapping the test instrument with the terminations at the opposite end.
 878
 879
 880
 881



882

883 **Figure 11 - Schematic diagram to measure channel AFEXT loss**

884 **4.7.10.3 Measurement of permanent link alien crosstalk**

885 The measurement of ANEXT loss and AFEXT loss in the permanent link configuration is
886 accomplished in the same manner as for the channel configuration described in 4.7.10.1 and
887 4.7.10.2 except that permanent link adapters replace the channel adapters and terminating plugs
888 are used as described in 4.7.8 to terminate the disturbed and disturbing permanent links under test.

889 **4.7.11 Processing measurement data**

890 The processing of the measured ANEXT loss or AFEXT loss is specified in this clause.

891 **4.7.11.1 Computing PSANEXT loss and PSAACRF**

892 **4.7.11.1.1 Computing PSANEXT loss and PSAACRF**

893 The PSANEXT loss shall be calculated in accordance with ANSI/TIA-568.5 requirements. Only
894 those ANEXT loss results that satisfy the significance condition per 4.7.11.2 shall be included.

895
896 The PSAACRF loss shall be calculated in accordance with ANSI/TIA-568.5 requirements. Only
897 those AFEXT loss results that satisfy the significance condition per 4.7.11.2 shall be included.

898
899 NOTE – Accumulated PSANEXT loss and PSAFEXT loss is computed sequentially by the
900 addition of disturbers to previously measured results.
901

902 **4.7.11.2 Significance condition testing**

903 This frequency range for Significance condition testing is only applicable to SP-II field test
904 instruments. For SP-I, the frequency range for checking significance is 0.1 MHz to 20 MHz (TBD).

905
906 Measurements in the 100 to 250 MHz frequency range shall be used to determine the significance
907 condition. The significance condition is determined from the average frequency response
908 expressed in dB between 100 MHz and 250 MHz. If the average measured ANEXT loss or AFEXT
909 loss between 100 MHz and 250 MHz exceeds 90 dB, then the entire ANEXT loss or AFEXT loss
910 response is excluded in the power sum computation. If the average measured ANEXT loss or
911 AFEXT loss between 100 MHz and 250 MHz does not exceed the significance condition, 90dB,
912 then the entire ANEXT loss or AFEXT loss response is included in the power sum computation.

913 **4.7.11.3 Applying measurement floor correction to alien crosstalk**

914 The frequency response for a large number of power sum alien crosstalk floor results may be used
915 to correct the calculated PSANEXT loss and PSAFEXT loss results. If the number of alien crosstalk
916 measurements in a power sum alien crosstalk result is greater than 6 disturbers (from 6 disturbing
917 channels), then the estimated measurement floor contribution to the overall power sum alien
918 crosstalk is calculated using equation (13). The measurement floor is defined in 4.7.7.

$$PSAXT_{Estimated_floor,Npp} = PSAXT_{Measurement_floor,Nps} + 10 \log \left(\frac{Nps}{Npp} \right) dB \quad (13)$$

919 where:
920 $PSAXT_{Measurement_floor,Nps}$ is the PSANEXT or PSAFEXT measurement floor in dB determined by
921 equation (13).

922
923 Npp is the number of alien crosstalk measurements included in the power sum calculations that
924 satisfy the significance condition.

925
926 Nps is the maximum expected number of disturbing channels.

927
928 The corrected PSANEXT loss result for a pair i is determined using equation (14):
929

$$PSANEXT_{corrected_i} = -10 \log \left(10^{-0.1 \cdot PSANEXT_i} - 10^{-0.1 \cdot PSAXT_{Estimated_{floor.Npp}}} \right) \text{ dB} \quad (14)$$

930
931
932

The corrected PSANEXT loss result for a pair i is determined using equation (15):

$$PSAFEXT_{corrected_i} = -10 \log \left(10^{-0.1 \cdot PSAFEXT_i} - 10^{-0.1 \cdot PSAXT_{Estimated_{floor.Npp}}} \right) \text{ dB} \quad (15)$$

933

934 4.8 Comparison measurement procedures

935 4.8.1 General

936 This clause describes procedures used to compare the results obtained using laboratory equipment
937 with those obtained with a field tester. The accuracy of this comparison is limited by the uncertainty
938 in the reference or laboratory measurement and the return loss, differential-to-common mode and
939 common mode-to-differential mode conversion properties of the link under test.

940

941 Field test requirements include the following parameters for which a measurement accuracy is
942 specified:

943

- 944 • Insertion loss (attenuation)
- 945 • Return loss
- 946 • TCL
- 947 • TCTL
- 948 • Propagation delay
- 949 • DC loop Resistance
- 950 • Alien NEXT (ANEXT)
- 951 • Alien FEXT (AFEXT)

952 4.8.2 General requirements

953 The reference test setup, calibration and measurement procedures are as described in this clause.

954 4.8.2.1 Test adapters

955 4.8.2.1.1 General

956 The following clauses describe a method for measuring link parameters in such a way that
957 measurements from the reference test setup can be compared directly with the results obtained
958 from a field tester.

959

960 The interface to laboratory test equipment is designed to accept copper cable ends of the balanced
961 single twisted-pair cabling to be tested or a mating connector. The interface to a field tester,
962 however, depends upon whether a permanent link, channel or the baseline configuration is to be
963 tested.

964


965 Special patch cords may be needed to compare the test results from a field tester and reference
966 test setup and are described in 4.8.2.1.2.

967

968 **4.8.2.1.2 Special patch cords**

969 A set of special patch cords may be used in order to be able to compare the results obtained with
970 laboratory equipment and field testers. The special patch cords have a high quality connection
971 inserted into the patch cord cable. This high quality connection consists of a test interface
972 connector and a mating connector. This connection is a low insertion loss (< 0.1 dB) connection.
973

974 For the channel and baseline test configurations, the length of the cable between the mating type
975 connector and the plug mating with the field tester should be 45 mm (1.77 in) maximum. The
976 instrument connector should be a modular connector when the channel configuration is tested. The
977 instrument connector should be a type that mates directly with the high quality measurement port
978 of the field tester as shown in Figure 12
979




980

981 **Figure 12 - Special patch cord for the baseline and channel test comparison**

982

983 For the permanent link test configurations, the length of the cable between the modular connector
984 and the plug mating with the link under test should be 45 mm (1.77 in) maximum. The instrument
985 connector should be a type that mates directly with the high quality measurement port of the field
986 tester as shown in Figure 13. Some methods used by field testers for permanent link
987 measurements rely on special calibration factors that are associated to a manufacturer's link
988 adapter (patch cord). The permanent link compensation can be rendered invalid if the link adapter
989 is physically modified or a test is run without valid calibration factors. Contact the field tester
990 manufacturer for any special precautions.
991

992



992

993 **Figure 13 - Special patch cord for permanent link test comparison**

994

995 When measuring a reference channel or permanent link with the field tester, the two sections of the
996 special patch cord should be mated with the test connector and mating connector. When
997 measuring the same link with the network analyzer, the two segments should be separated and the
998 mating connector directly inserted into the test interface as defined for the channel.

999 **4.8.2.2 Comparison methods**

1000 Field tester and network analyzer results can be compared using ANSI/TIA-568.5 compliant links

1001 whose transmission test performance falls within the dynamic range of the field tester. It is
1002 desirable that a number of links be used. A set of special patch cords that is appropriate for the
1003 type of comparison as described in ANSI/TIA-568.5 may be used. The results from the network
1004 analyzer and the field tester shall be compared using methods described in 4.8.2.2. The results
1005 shall agree within the sum of the measurement accuracy of the network analyzer measurement
1006 (See Annex A) and the measurement accuracy of the field tester, (See 4.4).
1007

1008 The requirements of insertion loss and return loss are specified as a function of frequency. The
1009 comparison may be applied to all frequency data points as described in 4.8.2.2.2. The performance
1010 of length, propagation delay, and dc loop resistance is expressed as a single number and
1011 comparison of measurement performance is described in 4.8.2.2.1.

1012 **4.8.2.2.1 Comparison method using worst case performance margin**

1013 The results obtained from the network analyzer and field tester over the specified frequency range
1014 are compared only at the worst case performance condition relative to the test limit for the link. It
1015 has been shown that small differences in the setup can cause shifts in the nulls in the frequency
1016 spectrum and slight variations in the maximum values between the nulls. The worst case
1017 performance margins shall agree within the sum of the measurement accuracies of the network
1018 analyzer and the field tester at the signal level of the worst case condition.

1019 **4.8.2.2.2 Comparison method using full frequency responses**

1020 For insertion loss a comparison of the difference of highest insertion loss values reported by the
1021 field tester and network analyzer against the sum of field tester and network analyzer measurement
1022 accuracies at or near the maximum frequency of the reporting range of the field tester is sufficient.
1023

1024 The full frequency response evaluation method is applicable to return loss. This method uses all
1025 data from the frequency response of the network analyzer and field tester that are within the
1026 minimum reporting range of the field tester.
1027

1028 The observed accuracy Acc_{obs} at every frequency data point, is computed by equation (16).
1029

$$Acc_{obs} = Limit + 20 \log \left(10^{\frac{-Limit}{20}} + \left| 10^{\frac{-R_{ft}}{20}} - 10^{\frac{-R_{nwa}}{20}} \right| \right) \quad (16)$$

1030

1031 where:

1032 Acc_{obs} is the observed measurement accuracy in dB.

1033 $Limit$ is the pass/fail limit for the test configuration (permanent link or channel) in dB.

1034

1035 R_{ft} is the reading by the field tester at the frequency of the data point in dB.


1036

1037 R_{nwa} is the reading by the network analyzer at the frequency of the data point in dB.

1038

1039 NOTE - Equation (16) computes the V/V equivalent noise floor from the difference of field
1040 tester and network analyzer readings; adds it to the V/V corresponding to the pass/fail limit;
1041 converts the total of a limit signal and equivalent noise signal back into a value in dB, and
1042 subtracts this value from the pass/fail limit itself to provide the observed accuracy at the
1043 pass/fail limit of the link under test.
1044

1045 An example of an observed accuracy plot is in Figure 14.
1046



1047

1048

1049

1050

1051

1052

1053

1054

1055

1056

1057

1058

Figure 14 - Example of observed Level SP-II accuracy

In Figure 14, the estimated measurement accuracy of a nominally compliant Level SP-II field tester, the estimated measurement accuracy of a network analyzer based measurement system, as well as the sum of network analyzer and nominally compliant field tester accuracies have been added to the observed measurement accuracies computed from the test data. The nominal measurement accuracy of the field tester is no worse than half the value in dB of what is predicted from computations that use performance parameters that are assumed worst case at all frequencies.

1059 **Annex A (informative) - Typical measurement accuracy of reference laboratory**
 1060 **measurement systems**

1061 It is necessary to establish the accuracy of measurements using laboratory equipment when
 1062 comparing measurements from field testers with those obtained using laboratory equipment. This
 1063 includes test fixture and test interface connections. Measurement accuracy is based upon the
 1064 assumptions for key performance parameters as shown in Table A.1. These are assumed to be
 1065 valid after two-port calibration of the test fixture and test interface connections. The performance at
 1066 key frequencies is shown in Table A.2. The properties for laboratory equipment can be measured
 1067 as described in 4.5.
 1068

1069 **Table A.1 - Typical laboratory equipment accuracy performance parameters**

Test parameter	Parameter	Performance (dB)
Insertion loss	Dynamic accuracy	0.2
	Source/load Return Loss	39 – 15 log($f/100$), 43 dB max. 20 dB min
ANEXT loss	Dynamic accuracy	0.2
	Source/load RL	39 – 15 log($f/100$), 43 dB max.
	Random Noise Floor	100
	Residual NEX	90 – 20 log($f/100$) 94 dB max ¹⁾ 70 dB min ¹⁾
	Output Signal Balance	50 – 20 log($f/100$)
AFEXT	Common Mode Rejection	50 – 20 log($f/100$)
	Dynamic accuracy	0.3
	Source/load RL	39 – 15 log($f/100$), 43 dB max.
	Random Noise Floor	100
	Residual FEXT	90 – 20 log($f/100$) 94 dB max ¹⁾ 70 dB min ¹⁾
Return loss	Output Signal Balance	50 – 20 log($f/100$)
	Common Mode Rej.	50 – 20 log($f/100$)
	Reflection Tracking	0.1
	Directivity	39 – 15 log($f/100$), 43 dB max. 20 dB min
	Source Match	50
	RL of termination	45 – 15 log($f/100$), 49 dB max. 20 dB min

¹⁾ Given in TIA 1183

1070

1071

Table A.2 - Measurement performance parameters at key frequencies (TBD)

Test parameter	Parameter	Performance at		
		0.1 MHz (dB)	20 MHz (dB)	600 MHz (dB)
Insertion loss	Dynamic accuracy	0.2	0.2	0.2
	Source/load RL	43.0	43.0	27.3
	Random Noise Floor	100.0	100.0	100.0
	Residual NEXT	94.0	94.0	74.4
	Output Signal Balance	50.0	50.0	34.4
	Common Mode Rej.	50.0	50.0	34.4
Return loss	Reflection Tracking	0.1	0.1	0.1
	Directivity	43.0	43.0	27.3
	Source Match	50.0	50.0	50.0
	RL of termination	49.0	49.0	33.3

1072

1073

1074

1075

1076

1077

1078

The absolute accuracy of the reference load depends largely upon the properties of the termination resistor, connection to the resistor, and the calibration standard. At low frequencies, the absolute performance is limited by the RF calibration standards. At high frequencies, the absolute performance is limited by the frequency response of the chip resistors and quality of termination. With appropriate care, 2 mm (.1 in) maximum untwist, an absolute return loss measurement floor as shown in Table A.3 can be expected.

1079

Table A.3 - Absolute reference load return loss (TBD)

Frequency (MHz)	Load absolute worst case return loss (dB)
1	43.0
4	43.0
8	43.0
10	43.0
16	43.0
20	43.0
25	43.0
31.25	43.0
62.5	42.0
100	39.0
150	36.4
200	34.5
250	33.0
500	28.5
600	27.3

1080

1081

1082

1083

This performance is used as the value of directivity and return loss of the remote termination in the determination of return loss measurement accuracy, and the source/load impedance for the determination of measurement accuracy for all other measurements.

1084

1085

1086

The predicted measurement accuracy will depend on the pass/fail limit of the link or component that is tested. An example of the measurement accuracy at key frequencies is shown in **Table A.4**, based on channel limits.

1087
 1088

Table A.4 - Predicted measurement worst case accuracy using laboratory equipment at channel limits (TBD)

Limits	Frequency (MHz)	Insertion loss (dB)	Return loss (dB)	TCL (dB)	TCTL (dB)
Level SP-I Channel	0.1	0.2	0.8	0.8	0.8
	1.0	0.2	0.7	0.7	0.7
	4.0	0.2	0.7	0.7	0.7
	8.0	0.2	0.7	0.7	0.7
	10.0	0.2	0.7	0.7	0.7
	16.0	0.2	0.7	0.7	0.7
	20.0	0.2	0.7	0.7	0.7
Level SP-II	1.0				
	4.0				
	8.0				
	10.0				
	16.0				
	20.0				
	25.0				
	31.25				
	62.5				
	100.0				
	125.0				
	150.0				
	200.0				
	250.0				
	300.0				
400.0					
500.0					
600.0					

1089
 1090
 1091


The appropriate pass/fail limit assumptions should be used to assess measurement accuracy when testing permanent links or components.

1092 **Annex B (informative) - Derivation of Level SP-I and SP-II Source Match and**
1093 **Reflection Tracking terms**

1094
1095 This annex provides the derivation for the source match and tracking terms used for Level SP-I and
1096 SP-II field tester accuracy calculations.

1097
1098 Figure B-1 presents a signal flow graph/error model for one-port VNA measurement. The model
1099 contains three error terms.

- 1100 1) D (directivity),
1101 2) M_s (source mismatch),
1102 3) T_r (frequency response reflection tracking).
1103



1104
1105 Figure B-1 - Error model for one-port VNA measurement
1106

1107 Using Kuhn's rules for the signal flow graph analyses [1], the mathematical relationship in
1108 Figure B-1 can be obtained as the following,
1109

$$S_{11m} = D + \frac{T_r S_{11A}}{1 - M_s S_{11A}} \quad (B.1)$$

1110 Here, S_{11m} is the measured reflection coefficient, and S_{11A} is the true/actual reflection coefficient of
1111 a standard. Then (B.1) can be transformed to,
1112
1113

$$(1 - M_s S_{11A}) S_{11m} = (1 - M_s S_{11A}) D + T_r S_{11A} \quad (B.2)$$

1114 Rearranging (B.2) ,
1115

$$S_{11A} = (S_{11m} - D) / [T_r + M_s (S_{11m} - D)] \quad (B.3)$$

1116
1117 When calibration standards, open, short, and load are used, Γ_{OA} , Γ_{SA} , and Γ_{LA} are their actual
1118 reflection coefficient, and Γ_{Om} , Γ_{Sm} , and Γ_{Lm} are the measured ones.
1119
1120

1121 Therefore, we can form three equations through open, short and load measurements.
1122
1123

$$(1 - M_s \Gamma_{OA}) \Gamma_{Om} = (1 - M_s \Gamma_{OA}) D + T_r \Gamma_{OA} \quad (B.4)$$

$$(1 - M_s \Gamma_{SA}) \Gamma_{Sm} = (1 - M_s \Gamma_{SA}) D + T_r \Gamma_{SA} \quad (B.5)$$

$$(1 - M_s \Gamma_{LA}) \Gamma_{Lm} = (1 - M_s \Gamma_{LA}) D + T_r \Gamma_{LA} \quad (B.6)$$

1124
1125 [(B.4) × Γ_{SA}] - [(B.5) × Γ_{OA}],

$$(1 - M_s \Gamma_{OA}) \Gamma_{Om} \Gamma_{SA} = (1 - M_s \Gamma_{OA}) D \Gamma_{SA} + T_r \Gamma_{OA} \Gamma_{SA} \quad (B.7)$$

$$(1 - M_s \Gamma_{SA}) \Gamma_{Sm} \Gamma_{OA} = (1 - M_s \Gamma_{SA}) D \Gamma_{OA} + T_r \Gamma_{SA} \Gamma_{OA} \quad (B.8)$$

1126

$$\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA} + M_s (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) = D (\Gamma_{SA} - \Gamma_{OA}) \quad (B.9)$$

1127
1128
1129 [(B.5) × Γ_{LA}] - [(B.6) × Γ_{SA}],
1130

$$(1 - M_s \Gamma_{SA}) \Gamma_{Sm} \Gamma_{LA} = (1 - M_s \Gamma_{SA}) D \Gamma_{LA} + T_r \Gamma_{SA} \Gamma_{LA} \quad (B.10)$$

$$(1 - M_s \Gamma_{LA}) \Gamma_{Lm} \Gamma_{SA} = (1 - M_s \Gamma_{LA}) D \Gamma_{SA} + T_r \Gamma_{LA} \Gamma_{SA} \quad (B.11)$$

1131

$$\Gamma_{Sm} \Gamma_{LA} - \Gamma_{Lm} \Gamma_{SA} + M_s (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) = D (\Gamma_{LA} - \Gamma_{SA}) \quad (B.12)$$

1132
1133
1134 [(B.9) × $(\Gamma_{LA} - \Gamma_{SA})$] - [(B.12) × $(\Gamma_{SA} - \Gamma_{OA})$],
1135

$$\begin{aligned} (\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA}) (\Gamma_{LA} - \Gamma_{SA}) + M_s (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) (\Gamma_{LA} - \Gamma_{SA}) \\ = D (\Gamma_{SA} - \Gamma_{OA}) (\Gamma_{LA} - \Gamma_{SA}) \end{aligned} \quad (B.13)$$

1136

$$\begin{aligned} (\Gamma_{Sm} \Gamma_{LA} - \Gamma_{Lm} \Gamma_{SA}) (\Gamma_{SA} - \Gamma_{OA}) + M_s (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) (\Gamma_{SA} - \Gamma_{OA}) \\ = D (\Gamma_{LA} - \Gamma_{SA}) (\Gamma_{SA} - \Gamma_{OA}) \end{aligned} \quad (B.14)$$

1137

$$M_s = \frac{(\Gamma_{Sm} \Gamma_{LA} - \Gamma_{Lm} \Gamma_{SA}) (\Gamma_{SA} - \Gamma_{OA}) - (\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA}) (\Gamma_{LA} - \Gamma_{SA})}{(\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) (\Gamma_{LA} - \Gamma_{SA}) - (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) (\Gamma_{SA} - \Gamma_{OA})} \quad (B.15)$$

1138
1139
1140 [(B.9) × $(\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA})$] - [(B.12) × $(\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA})$],
1141

$$\begin{aligned} (\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA}) (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) + M_s (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} \\ - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) = D (\Gamma_{SA} - \Gamma_{OA}) (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) \end{aligned} \quad (B.16)$$

1142

$$\begin{aligned} (\Gamma_{Sm} \Gamma_{LA} - \Gamma_{Lm} \Gamma_{SA}) (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) + M_s (\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} \\ - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) = D (\Gamma_{LA} - \Gamma_{SA}) (\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA}) \end{aligned} \quad (B.17)$$

1143

$$D = \frac{(\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}{(\Gamma_{SA} - \Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{LA} - \Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})} \quad (B.18)$$

1144
1145
1146

Rearranging (B.1) & replacing with actual and measured reflection coefficient for OPEN standard,

$$\left(\frac{1}{\Gamma_{OA}} - M_s\right)(\Gamma_{Om} - D) = T_r \quad (B.19)$$

1147

$$T_r = \left(\frac{1}{\Gamma_{OA}} - \frac{(\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA} - \Gamma_{OA}) - (\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA} - \Gamma_{SA})}{(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})(\Gamma_{LA} - \Gamma_{SA}) - (\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA})(\Gamma_{SA} - \Gamma_{OA})}\right) \times$$

$$\left(\Gamma_{Om} - \frac{(\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}{(\Gamma_{SA} - \Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{LA} - \Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}\right) \quad (B.20)$$

1148 Simplifications

1149 1) Tracking

$$T_r = \left(\frac{1}{\Gamma_{OA}} - \frac{(\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA} - \Gamma_{OA}) - (\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA} - \Gamma_{SA})}{(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})(\Gamma_{LA} - \Gamma_{SA}) - (\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA})(\Gamma_{SA} - \Gamma_{OA})}\right) \times$$

$$\left(\Gamma_{Om} - \frac{(\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}{(\Gamma_{SA} - \Gamma_{OA})(\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA}) - (\Gamma_{LA} - \Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}\right) \quad (B.21)$$

1150 For ideal open, short and load we have $\Gamma_A = 1, -1, 0$

$$T_r = \left(1 - \frac{-2\Gamma_{Lm} - (-\Gamma_{Om} - \Gamma_{Sm})}{\Gamma_{Om} - \Gamma_{Sm}}\right) \times \left(\Gamma_{Om} - \frac{-(-\Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}{-(\Gamma_{LA} - \Gamma_{SA})(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})}\right) \quad (B.22)$$

1151

1152 That is,

$$T_r = \left(\frac{2\Gamma_{Lm} - 2\Gamma_{Sm}}{\Gamma_{Om} - \Gamma_{Sm}}\right) \times (\Gamma_{Om} - \Gamma_{Lm}) \quad (B.23)$$

1153 Final form is,

$$T_r = 2 \left(\frac{\Gamma_{Lm} - \Gamma_{Sm}}{\Gamma_{Om} - \Gamma_{Sm}}\right) \times (\Gamma_{Om} - \Gamma_{Lm}) \quad (B.24)$$

1154

1155

1156 2) Source Match

$$M_s = \frac{(\Gamma_{Sm}\Gamma_{LA} - \Gamma_{Lm}\Gamma_{SA})(\Gamma_{SA} - \Gamma_{OA}) - (\Gamma_{Om}\Gamma_{SA} - \Gamma_{Sm}\Gamma_{OA})(\Gamma_{LA} - \Gamma_{SA})}{(\Gamma_{SA}\Gamma_{Sm}\Gamma_{OA} - \Gamma_{OA}\Gamma_{Om}\Gamma_{SA})(\Gamma_{LA} - \Gamma_{SA}) - (\Gamma_{LA}\Gamma_{Lm}\Gamma_{SA} - \Gamma_{SA}\Gamma_{Sm}\Gamma_{LA})(\Gamma_{SA} - \Gamma_{OA})} \quad (B.25)$$

1157

1158 For ideal open, short and load we have $\Gamma_A = 1, -1, 0$

1159 Due to $\Gamma_{LA} = 0$,
1160

$$M_s = \frac{\Gamma_{Lm} (\Gamma_{SA} - \Gamma_{OA}) - (\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA})}{(\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA})} \quad (B.26)$$

1161
1162
1163 Then,

$$M_s = \frac{\Gamma_{Om} + \Gamma_{Sm} - 2\Gamma_{Lm}}{\Gamma_{Om} - \Gamma_{Sm}} \quad (B.27)$$

1164
1165
1166 3) Directivity

$$D = \frac{(\Gamma_{Om} \Gamma_{SA} - \Gamma_{Sm} \Gamma_{OA})(\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) - (\Gamma_{Sm} \Gamma_{LA} - \Gamma_{Lm} \Gamma_{SA})(\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA})}{(\Gamma_{SA} - \Gamma_{OA})(\Gamma_{LA} \Gamma_{Lm} \Gamma_{SA} - \Gamma_{SA} \Gamma_{Sm} \Gamma_{LA}) - (\Gamma_{LA} - \Gamma_{SA})(\Gamma_{SA} \Gamma_{Sm} \Gamma_{OA} - \Gamma_{OA} \Gamma_{Om} \Gamma_{SA})} \quad (B.28)$$

1167 For ideal open, short and load we have $\Gamma_A = 1, -1, 0$

1168 Due to $\Gamma_{LA} = 0$

$$D = \Gamma_{Lm} \quad (B.29)$$

1169

1170 **Annex C (informative) - Bibliography**

1171 The organizations listed below can be contacted to obtain reference information.

1172 ANSI

1173 www.ansi.org

1174 BICSI

1175 www.bicsi.org

1176 TIA

1177 www.tiaonline.org

1178 The following reference may provide additional useful information:

1179 [1]. P. Young, "Scattering coefficients and circuit analysis," in *14th IEE Microwave Measurements*
1180 *Training Course*, pp.2 -2/11, May 2005.

1181 [2]. ANSI/TIA-1183-1 Measurement methods and test fixtures for balun-less measurements of
1182 balanced components and systems extending frequency capabilities to 2GHz.

DRAFT